



Specifications

| |
|---|
| Input Voltage: 24 VAC (Supplied with Multi-tap Transformer) |
| Power Consumption: 36 Va |
| Total Ion Output: > 1.92 Billion +/- Ions/cc |
| Needle Point Count: 12 Total, 6 Positive / 6 Negative |
| Ionizer Module Replacement Part #: 94-018 |



| | | | |
|---|---|--------------------------|--------|
| Ultravation, Inc. 212 Ideal Way Poultney, Vermont 05764 Ph: 802-287-9735 Fx: 802-287-9203 www.Ultravation.com | Part #: CIS36 | Drawing #: UVM-CIS36-DSS | Rev -* |
| | Description: UVMMatrix CIS 36 with 12 needle point bipolar ionization system. 24 VAC with a supplied multi-tap transformer, Internal or External mounting for systems 30 to 36 ton. | | |
| Date: 2/12/21 | Scale: NTS | Creator: JSM | |